

August 15, 2008

Mr. John F. Prochilo  
CEO/Administrator  
Northeast Rehabilitation Hospital  
70 Butler Street  
Salem, NH 03079

**Re: Issuance of General State Permit: GSP-EG-155**  
**Source Category: Internal Combustion Engines Used As Emergency Generators**  
**AFS #3301500108 Application #08-0279**  
**Neuro-Rehab Associates, Inc. d/b/a Northeast Rehabilitation Hospital**  
**70 Butler Street, Salem, NH 03079**

Dear Mr. Prochilo:

The New Hampshire Department of Environmental Services, Air Resources Division (DES) hereby issues the enclosed General State Permit in accordance with the New Hampshire Code of Administrative Rules Env-A 610, *General State Permits and General Permits under Title V*. This General State Permit is issued specifically for the following device as described in the permit application submitted by Northeast Rehabilitation Hospital and received by DES on August 1, 2008:

Device	Make/Model/ Serial No.	Year Installed	Fuel(s)	Max. Heat Input Rate MMBtu/hr	Max. Fuel Use Rate gal/hr	Output Rating
EG No. 1	Caterpillar 341ZDIT Serial No. 81Z03880	1984	No. 2 oil or Diesel	2.65	18.9	702 kW

The General State Permit for Internal Combustion Engines Used As Emergency Generators is viewable online at the following Web address: <http://des.nh.gov/ard/GSP/GSP-EG.pdf>.

Please note that the enclosed permit expires on **April 30, 2013**. If you wish to continue operation of the device beyond April 30, 2013, you must apply for permit renewal in accordance with Env-A 610.12, *Expiration Date and General State Permit Reestablishment Procedures*.

If you have any questions, please contact Colleen Higgins of the Air Resources Division, Permitting and Environmental Health Bureau, at (603) 271-0683 or via email at [colleen.higgins@des.nh.gov](mailto:colleen.higgins@des.nh.gov).

Sincerely,



Robert R. Scott  
Director  
Air Resources Division

Cert. mail # 70063450000160184577  
rrs/ceh

encl: General State Permit: Internal Combustion Engines Used As Emergency Generators