



ANALYTICAL RESULTS

Batch ID/Form: 144937 - LEAD AND COPPER RULE

Submitting Lab ID: 1012

PWS ID/Name: 0351010 - CANAAN WATER DEPT - CANAAN

Report Date: 07/08/2015

Collector: JOHN COFFEY

Phone: 603-523-9501

Collect Date: 06/19/2015 07:00:00

Lab Sample ID: 144937.13

Matrix: WATER

Received: 06/24/2015 14:52

Sample Location ID: 17

Sample Type: ROUTINE-SAMPLE

Compliance Period: Q2 2015

Description: 18 LABRADOR LANE

Receipt Temp.: 6.4 C

Analyte	Results	Units	RDL	DF	Prepared Date	Analysis Date	Analyte Code	Analyst	Qual.
Analytical Method: 10014605		Analyzing Lab: 1012-EASTERN ANALYTICAL INC							
COPPER, TOTAL	0.24	MG/L	.001	1		06/26/2015 05:58:38	1022		
LEAD, TOTAL	0.069	MG/L	.001	1		06/26/2015 05:58:38	1030		

This report is derived from the original 'Report of Laboratory Analysis' and is not intended as a replacement.