EAI ANALYTICAL LABS
640 MARLBORO ST. RTE. 101
Swanzey NH 03446
Phone: (603) 357-2577
Fax: (603) 352-3899

ANALYTICAL RESULTS

Batch ID/Form: 53977 - TOTAL COLIFORM RULE **Submitting Lab ID:** 1007

PWS ID/Name: 2531010 - WINCHESTER WATER DEPT - WINCHESTER **Report Date:** 02/11/2016

Collector: RICK MELESKI **Phone:** 603-239-4951 EXT. 105 **Collect Date:** 02/04/2016 09:45

Lab Sample ID: 53977 **Matrix:** DRINKING WATER **Received:** 02/04/2016 10:40

Sample Location ID: 008 **Sample Type:** ROUTINE-SAMPLE **Compliance Period:** FEB 2016

Description: WINCHESTER SEWER PUMP STATION **Receipt Temp.:** 10.1 C

Analyte	Results	Units	RDL	DF	Prepared Date	Analysis Date	Analyte Code	Analyst	Qual.
Analytical Method: 20212208			**Analyzing Lab: 1007-EAI ANALYTICAL LABS**						
ESCHERICHIA COLI	ABSENT	P-A/100ML			02/04/2016 17:00	02/05/2016 17:00	2525		
TOTAL COLIFORMS	ABSENT	P-A/100ML			02/04/2016 17:00	02/05/2016 17:00	2500		
Analytical Method: Field Result									
FREE CHLORINE RESIDUAL	0.02	MG/L							

This report is derived from the original 'Report of Laboratory Analysis' and is not intended as a replacement.